

certificate
no. **IFA 2004163**
dated 2020-06-10

Translation In any case, the German original shall prevail.

DGUV Test Certificate

Name and address of the holder of the certificate (customer): STACO Holding B.V.
Molenweg 1
5953 Reuver
NETHERLANDS

Product designation: **Perforated metal planks, hot-dip galvanized**

Type: AP ...x30/RUN

Testing based on: Testing of floor coverings – Determination of the anti-slip property according to DIN 51130 (02.2014) and ASR A1.5/1,2


Test report: Test Certificate No. 2020 22132/3210 dated 2020-06-10
- IFA, Sankt Augustin

Further details: Intended purpose:
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R11/V10 are specified.

Remarks: "Duplicate"
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.
The present certificate including the right to affix the DGUV Test mark is valid until: **2025-06-09**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.



Dr. rer. nat. Peter Paszkiewicz
Head of testing and certification body



Dipl.-Ing. Olaf Mewes
Certification Officer