

certificate  
no. **IFA 2304004**  
dated 2023-01-10



Institut für Arbeitsschutz der  
Deutschen Gesetzlichen Unfallversicherung  
Prüf- und Zertifizierungsstelle im DGUV Test

Translation In any case, the German original shall prevail.

## DGUV Test Certificate

Name and address of the holder of the certificate (customer):  
STACO Holding B.V.  
Molenweg 1  
5953 Reuver  
NETHERLANDS

Product designation: **Gratings made of aluminium**

Type: RR 33x33 RVA \*BB 40x2/CB 10x2

Testing based on:  
DIN EN 16165:2021-12 annex B; Determination of slip resistance of pedestrian surfaces - Shod ramp test  
ASR A1.5/1.2; Technical rules for workplaces – floorings; Edition: March 2022  
E DIN 51133:2021-12 - Testing of floor coverings - Determination of the displacement space

Test report: No. 2023 20079/3210 dated 2023-01-10  
- IFA, Sankt Augustin

Further details:

Intended purpose:  
Floor covering for use in working areas presenting a risk of slipping, for which floor coverings of slip resistance assessment group R13/V10 are specified.  
Remarks:  
The DGUV test mark may be used only in conjunction with indication of the slip resistance assessment group and the displacement space.

The type tested complies with the test basis specified above. The holder of the certificate is entitled to affix the DGUV Test mark shown overleaf to the products complying with the type tested, including the specification given under the heading further details.  
The present certificate including the right to affix the DGUV Test mark is valid until: **2028-01-09**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.

  
Dr. rer. nat. Peter Paszkiewicz  
Head of testing and certification body

  
Dipl.-Ing. Olaf Mewes  
Certification Officer

---

## DGUV Test mark

---

